

June 25, 2024
PATTS COLLEGE OF AERONAUTICS
Lambo St. San Dionisio Parañaque City
0995-365-0589

Please be informed that the air-conditioner you intend to purchase is under capacity as compared to the following unit that we proposed:

Location	Area	Kolin's Recommendation	Customer's Choice	Remarks
Office of Student Affairs	110	KLG-SF40-WBR6H1M32 (1 unit) KSG-IWF-30WFY8K1M32 (2 units)	KLG-SF40-WBR6H1M32 (1 unit) KSM-SW25-6H1M32-A (1 unit)	Calculated capacity 9.4HP, undersize by 2.9HP

Since the unit of your choice is under capacity, it is probable that you may experience the following:

1. Capacity of the unit to cool the area will take longer or it will not cool the area at all that may lead to your dissatisfaction with the cooling performance of our unit.
2. Power consumption will be higher due to frequent running of compressor for not reaching the desired temperature within the normal parameter.
3. Useful life of compressor will be shortened due to excessive running beyond the normal run cycle.

Considering the above conditions, we regret to inform you that we cannot guarantee the efficient performance of unit. **Also, One (1) year warranty for parts (compressor-1year).**

For your guidance and information

Prepared by:

Jeoffrey Dadios
Surveyor

Approved by:

Mr. Alvin de Rivera
Service Manager

June 25, 2024

Noted by:

Engr. Kenneth Zamora
Service Supervisor
Field and Shop Operation

Customer Conforme:

Signature Over Printed Name