

August 30, 2024

STATE ENTERPRISES

7532 Cruz Compound, Dr. A. Santos Ave. Brgy San Isidro Sucat Paranaque City

Please be informed that the air-conditioner you intend to purchase is under capacity as compared to the following unit that we proposed:

Location	Area	Kolin's Recommendation	Customer's Choice	Remarks
WAREHOUSE	148.4 sqm	KLG-IF100-4F3M410	KLG-IF70-5G1M32	Calculated 9.4hp under by 2.4hp

Since the unit of your choice is under capacity, it is probable that you may experience the following;

1. Capacity of the unit to cool the area will take longer or it will not cool the area at all that may lead to your dissatisfaction with the cooling performance of our unit.
2. Power consumption will be higher due to frequent running of compressor for not reaching the desired temperature within the normal parameter.
3. Useful life of compressor will be shortened due to excessive running beyond the normal run cycle.


Considering the above conditions, we regret to inform you that we cannot guarantee the efficient performance of unit. **Also, One (1) year warranty for parts (compressor-1year).**

For your guidance and information


Prepared by:

Jeoffrey T. Dadios
Surveyor

Approved by:


Mr. Arvin de Rivera
Service Manager
Aug.30,2024

Noted by:


Engr. Kenneth Zamora
Service Supervisor - Field
and Shop Operation

Customer Conforme:

Signature Over Printed Name