N.V.F.S MAINTENANCE AIRCON & REFRIGERATION SYSTEM TRADING
MANILA: Office Unit Q Monserrat St B.F. Homes Phase 1 Sucat Rd Paranaque
09171163534 | 09455920222 | 02 85146379
sales@about-nvfs-ph.com inquiry@about-nvfs-ph.com
www.nvfs-ph.com

kolin
AUTHORIZED SERVICE CENTER

Model No: KAM-100DRC32 / KA-200MCARINV32 D.O.P.
S/S (I): 191B2501-11978 S/S (O): 23022406-15266
Product Type:

Permit ☐ Appointment ☐
Ladder ☐ Trolley ☐
Parking ☐ O.R ☐
Location:

Service Job Report No: HO-00253795 Date: 5th May 2025 Time In: Time Out:

Place of Service:

☐ Hotel ☐ Apartment ☐ School ☐ Factory ☐ Retail Shop
☐ House ☐ Hospital/Clinic ☐ Shopping Mall ☐ Community ☐ Commercial Shop
☐ Office ☐ Restaurant ☐ Warehouse ☐ Club House ☐ Construction Site
☐ Airport ☐ Airport Cargo ☐ Training Room ☐ Container Van ☐ Production Area

Client: Aranas Cruz Araneta Parker Faustino Law Offices
Address: , 18 Jasmin St., Tahanan Village, Brgy. BF Homes, PARAÑAQUE CITY, Metro Manila
Email:
Customer ID:
Contract No:
Mobile No. 0999-2298705

PARAMETERS	Before	After
Room Temperature / Mode Settings(Cool)	COOL	
WAC/ Settings Temp (16°c-RE)(10-ME)	16	
SAC/PAC Settings Temp °c		
Discharge Temperature °c	14	
FC / Intake Temperature °c	24	
Ampere	4.1	
WAC/ Wattage (Inverter)		
SAC/PAC / Preassure		
Voltage	230	

Findings

Recommendation

Service Report History:

Date Attended:	SJR No:	Job Service History:
24th April 2025	HO-00251964	Installation of 4 WAC
5th May 2025	HO-00253795	Backjob / complain bad Installation

Parts Code	Description	Qty	Unit Price	Amount

Repair Done: FIXED THE FRAME AND CRACKS

Labor	
Handling	
Others	
Discount	
Others	
Total	
Amount Paid	
Balance	

Client's Name / Authorized Representative: Signature:

Authrized Service Center Representative: alex / amang Signature:

REPAIR COMPLETED		WARRANTY NO OF MONTHS					
		3	6	12	24	36	60
YES	N/A						

CBR WTY

AUTHORISED SERVICE CENTER

Panasonic kolin TOSHIBA

Midea GREE AUX

NVFS Maintenance Aircon & Refrigeration System Trading
Unit Q Monserrat St BF Homes Phase 1 Sucat
Paranaque, Paranaque 0000
+639171163534
inquiry@about-nvfs-ph.com
www.nvfs-ph.com

INVOICE

BILL TO
Aranas Cruz Araneta Parker
Faustino Law Offices
, 18 Jasmin St., Tahanan
Village, Brgy. BF Homes,
PARAÑAQUE CITY, Metro
Manila

INVOICE NO. 3548
DATE 04/24/2025
DUE DATE 04/24/2025

DATE	ACTIVITY	DESCRIPTION	QTY	RATE	AMOUNT	SKU
04/24/2025	**KOLIN Window Type Basic Installation**	KOLIN Window Type Basic Installation Mounting / Gap Sealant / Minor adjustment and plastering of gap (No Chipping works and Major Modification)	4	1,200.00	4,800.00	5

PAYMENT OPTIONS :

BALANCE DUE **PHP4,800.00**

SOA

Bank transfer: BDO account 004128020472
Bank transfer : Metrobank Account 034-7-03452574-5
Bank Transfer: BPI Account 5979-0078-51
Gcash : 0915-617-8820
Maya : 0917-188-9222
Cheque Payable to: NVFS Maintenance Aircon & Refrigeration System Trading

FOR SOA

WARRANTY: 3 Months for LABOR and PARTS replaced.

NOTE: No warranty claim provided if not repaired or replaced by an Authorized Service Center.

CamScanner

N.V.F.S MAINTENANCE AIRCON & REFRIGERATION SYSTEM TRADING
MANILA: Office Unit Q Monserrat St B.F. Homes Phase 1 Sucat Rd Paranaque
09171163534 | 09455920222 | 02 85146379
sales@about-nvfs-ph.com inquiry@about-nvfs-ph.com
www.nvfs-ph.com

kolin
AUTHORIZED SERVICE CENTER

Model No: KAM-100DRC32 D.O.P
S/S (I) 23022406-15268 S/S (O)
Product Type KOLIN

Permit ☐ Appointment ☐
Ladder ☐ Trolley ☐
Parking ☐ O.R ☐

Location :

Service Job Report No: HO-00251964 Date : 24th April 2025 Time In: Time Out:

Place of Service:

☐ Hotel	☐ Apartment	☐ School	☐ Factory	☐ Retail Shop
☐ House	☐ Hospital/Clinic	☐ Shopping Mall	☐ Community	☐ Commercial Shop
☐ Office	☐ Restaurant	☐ Warehouse	☐ Club House	☐ Construction Site
☐ Airport	☐ Airport Cargo	☐ Training Room	☐ Container Van	☐ Production Area

Client : Aranas Cruz Araneta Parker Faustino Law Offices
Customer ID:
Address : , 18 Jasmin St., Tahanan Village, Brgy. BF Homes, PARAÑAQUE CITY, Metro Manila
Contract No:
Email:
Mobile No. 0999-2298705

PARAMETERS	Before	After
Room Temperature / Mode Settings(Cool)	COOL	
WAC/ Settings Temp (16°c-RE)(10-ME)	16	
SAC/PAC Settings Temp °c		
Discharge Temperature °c	19	
FC / Intake Temperature °c	29	
Ampere	3.8A	
WAC/ Wattage (Inverter)		
SAC/PAC / Preassure		
Voltage	230	

Findings

Recommendation

Service Report History:

Job Service History:

Date Attended : 24th April 2025 SJR No: HO-00251964 Installation of 4 WAC

Parts Code	Description	Qty	Unit Price	Amount
	Basic Installation	4	1200	₱4,800.00

Repair Done : INSTALLATION OF AC UNIT WINDOW -TYPE DOHE UNIT OK

Labor	
Handling	
Others	
Discount	
Others	
Total	₱4,800.00
Amount Paid	
Balance	

Client's Name / Authorized Representative: Ronald Montibon Signature:

Authrized Service Center Representative : CHRIST / JAKE Signature:

REPAIR COMPLETED		WARRANTY NO OF MONTHS					
		3	6	12	24	36	60
YES	N/A						

FOR SOA

CamScanner

N.V.F.S MAINTENANCE AIRCON & REFRIGERATION SYSTEM TRADING
MANILA: Office Unit Q Monserrat St B.F. Homes Phase 1 Sucat Rd Paranaque
09171163534 | 09455920222 | 02 85146379
sales@about-nvfs-ph.com inquiry@about-nvfs-ph.com
www.nvfs-ph.com

kolin
AUTHORIZED SERVICE CENTER

Model No: KA-200MCARINV32 D.O.P
S/S (I) 19182501-11978 S/S (O)
Product Type KOLIN

Permit [ ] Appointment [ ]
Ladder [ ] Trolley [ ]
Parking [ ] O.R [ ]

Location: MASTER BED

Service Job Report No: HO-00251966 Date: 24th April 2025 Time In: Time Out:

Place of Service:

[ ] Hotel	[ ] Apartment	[ ] School	[ ] Factory	[ ] Retail Shop
[ ] House	[ ] Hospital/Clinic	[ ] Shopping Mall	[ ] Community	[ ] Commercial Shop
[ ] Office	[ ] Restaurant	[ ] Warehouse	[ ] Club House	[ ] Construction Site
[ ] Airport	[ ] Airport Cargo	[ ] Training Room	[ ] Container Van	[ ] Production Area

Client: Aranas Cruz Araneta Parker Faustino Law Offices
Address: , 18 Jasmin St., Tahanan Village, Brgy. BF Homes, PARAÑAQUE CITY, Metro Manila
Email:
Customer ID:
Contract No:
Mobile No. 0999-2298705

PARAMETERS	Before	After	Findings
Room Temperature / Mode Settings(Cool)			
WAC/ Settings Temp (16°c-RE)(10-ME)			
SAC/PAC Settings Temp °c			
Discharge Temperature °c			
FC / Intake Temperature °c			Recommendation
Ampere			
WAC/ Wattage (Inverter)			
SAC/PAC / Preassure			
Voltage			

Service Report History:

Date Attended:	SJR No:	Job Service History:
24th April 2025	HO-00251966	Installation of 4 WAC

Parts Code	Description	Qty	Unit Price	Amount
	Basic Installation	4	1200	₱4,800.00

Repair Done: INSTALLATION OF AC UNIT WINDOW TYPE, DONE UNIT OK

Labor	
Handling	
Others	
Discount	
Others	
Total	₱4,800.00
Amount Paid	
Balance	

REPAIR COMPLETED		WARRANTY NO OF MONTHS					
YES	N/A	3	6	12	24	36	60

Client's Name / Authorized Representative: Ronald Montibon Signature: [signature]

Authrized Service Center Representative: CHRIST/JAKE Signature: [signature]

FOR SOA

N.V.F.S MAINTENANCE AIRCON & REFRIGERATION SYSTEM TRADING
MANILA: Office Unit Q Monserrat St B.F. Homes Phase 1 Sucat Rd Paranaque
09171163534 | 09455920222 | 02 85146379
sales@about-nvfs-ph.com inquiry@about-nvfs-ph.com
www.nvfs-ph.com

kolin
AUTHORIZED SERVICE CENTER

Model No: KAM-100DRC32 D.O.P ______
S/S (I) 23022406-15547 S/S (O) ______
Product Type KOLIN

Permit [ ] Ladder [ ] Parking [ ] Appointment [ ] Trolley [ ] O.R [ ]
Location: ______

Service Job Report No: HO-00251963 Date: 24th April 2025 Time In: ______ Time Out: ______

Place of Service:

- [ ] Hotel
- [ ] House
- [ ] Office
- [ ] Airport
- [ ] Apartment
- [ ] Hospital/Clinic
- [ ] Restaurant
- [ ] Airport Cargo
- [ ] School
- [ ] Shopping Mall
- [ ] Warehouse
- [ ] Training Room
- [ ] Factory
- [ ] Community
- [ ] Club House
- [ ] Container Van
- [ ] Retail Shop
- [ ] Commercial Shop
- [ ] Construction Site
- [ ] Production Area

Client: Aranas Cruz Araneta Parker Faustino Law Offices
Address: , 18 Jasmin St., Tahanan Village, Brgy. BF Homes, PARAÑAQUE CITY, Metro Manila
Email:
Customer ID:
Contract No:
Mobile No. 0999-2298705

PARAMETERS	Before	After
Room Temperature / Mode Settings(Cool)	COOL	
WAC/ Settings Temp (16°c-RE)(10-ME)	16	
SAC/PAC Settings Temp °c		
Discharge Temperature °c	19	
FC / Intake Temperature °c	29	
Ampere	3.8A	
WAC/ Wattage (Inverter)		
SAC/PAC / Preassure		
Voltage		

Findings:

Recommendation:

Service Report History:

Job Service History:

Date Attended:	SJR No:	Job Service History
24th April 2025	HO-00251963	Installation of 4 WAC

Parts Code	Description	Qty	Unit Price	Amount
	Basic Installation	4	1200	₱4,800.00

Repair Done: INSTALLATION OF AC UNIT WINDOW TYPE DONE UNIT OK

Labor	
Handling	
Others	
Discount	
Others	
Total	₱4,800.00
Amount Paid	
Balance	

REPAIR COMPLETED		WARRANTY NO OF MONTHS					
YES	N/A	3	6	12	24	36	60

Client's Name / Authorized Representative: Ronald Manalo Signature: [signature]

Authrized Service Center Representative: CHRIST / JAKE Signature: [signature]

FOR SOA

N.V.F.S MAINTENANCE AIRCON & REFRIGERATION SYSTEM TRADING
MANILA: Office Unit Q Monserrat St B.F. Homes Phase 1 Sucat Rd Paranaque
09171163534 | 09455920222 | 02 85146379
sales@about-nvfs-ph.com inquiry@about-nvfs-ph.com
www.nvfs-ph.com

kolin
AUTHORIZED SERVICE CENTER

Model No: KA-100MCARINV32 D.O.P
S/S (I) 19162412-13476 S/S (O)
Product Type ICOLIN

Permit ☐ Appointment ☐
Ladder ☐ Trolley ☐
Parking ☐ O.R ☐

Location :

Service Job Report No: HO-00251967 **Date :** 24th April 2025 **Time In:** **Time Out:**

Place of Service:

☐ Hotel	☐ Apartment	☐ School	☐ Factory	☐ Retail Shop
☐ House	☐ Hospital/Clinic	☐ Shopping Mall	☐ Community	☐ Commercial Shop
☐ Office	☐ Restaurant	☐ Warehouse	☐ Club House	☐ Construction Site
☐ Airport	☐ Airport Cargo	☐ Training Room	☐ Container Van	☐ Production Area

Client :	Aranas Cruz Araneta Parker Faustino Law Offices	**Customer ID:**	
Address :	, 18 Jasmin St., Tahanan Village, Brgy. BF Homes, PARAÑAQUE CITY, Metro Manila	**Contract No:**	
Email:		**Mobile No.**	0999-2298705

PARAMETERS	Before	After	Findings
Room Temperature / Mode Settings(Cool)	COOL		
WAC/ Settings Temp (16°c-RE)(10-ME)	16		
SAC/PAC Settings Temp °c			
Discharge Temperature °c	19		
FC / Intake Temperature °c	24		**Recommendation**
Ampere	3.5 AMP		
WAC/ Wattage (Inverter)			
SAC/PAC / Preassure			
Voltage	230		

Service Report History:

Date Attended :	SJR No:	Job Service History:
24th April 2025	HO-00251967	Installation of 4 WAC

Parts Code	Description	Qty	Unit Price	Amount
	Basic Installation	4	1200	₱4,800.00

Repair Done : INSTALLATION OF AC UNIT WINDOW TYPE DONE UNIT OK

Labor	
Handling	
Others	
Discount	
Others	
Total	₱4,800.00
Amount Paid	
Balance	

REPAIR COMPLETED		WARRANTY NO OF MONTHS					
		3	6	12	24	36	60
YES	N/A						

Client's Name / Authorized Representative: Signature:

Authrized Service Center Representative : CHRIST JADE Signature:

FOR SOA

CamScanner