

KOLIN Philippines International Inc.
Survey Form

No 003445

Customer Name: VIRGIE ONG Date: 4-16-14
 Address: 1 SAN LEONARDOS ST. EX 56 BWD. CANTERA SJR No.: 198304
VILLAGE DIAMAS, PAGO
 Establishment Type: Residential ☒ Area Surveyed: MASTER BEDROOM
 Commercial ☐ Area Surveyed: _____
 Recommended Product Model: KSL 1WF-30W/F 8K/M32

Cooling Capacity Computation

Floor Area: 27 sqm.
 Ceiling Height: 2.7 mtr.

note: add 20% per meter in excess of 3 meters in the initial cooling capacity computed.

Floor Area:	<u>27</u>	x	550 Btu/h	<u>14850</u>	Btu/h
Ceiling Height (excess of 3 mtrs.):		x	20%		Btu/h
Window Direct Sunlight		x	20% - 50%	<u>2970</u>	Btu/h
Total Cooling Capacity				<u>17820</u>	Btu/h

Add : Additional Heat Load

No. of Person	<u>2</u>	x	300 Btu/h	<u>600</u>	Btu/h
No. of Ordinary Light (<40w)	<u>6</u>	x	200 Btu/h	<u>1200</u>	Btu/h
No. of Special Light (>40w)		x	400 Btu/h		Btu/h
No. of Refrigerator (< 6 cu.ft.)		x	400 Btu/h		Btu/h
No. of Refrigerator (> 6 cu.ft.)		x	800 Btu/h		Btu/h
No. of Cooking Range		x	1500 Btu/h		Btu/h
No. of Laptop Computer		x	150 Btu/h		Btu/h
No. of Desktop Computer <u>1</u>	<u>1</u>	x	400 Btu/h	<u>400</u>	Btu/h
No. of Printer		x	500 Btu/h		Btu/h
No. of Photocopier		x	1000 Btu/h		Btu/h
Total Cooling Capacity				<u>2200</u>	Btu/h

Recommended Cooling Capacity

2.3
20020 Btu/h


Note : Compressor warranty will be reduced to ____ yr. if air-conditioner purchased is lower than the recommended cooling capacity or pipe lay-out is beyond the maximum allowable length.

Scope of Work Agreement

- | | | |
|-----------------------------------|--|--|
| 1. Copper tube lay-out | ☒ Expose | ☐ Embedded |
| 2. Chipping | ☐ Included | ☒ Not Included |
| 3. Fabricated Bracket | ☐ Yes ☐ Shop | ☐ Site ☒ No |
| 4. Service Ledge | ☐ Yes | ☒ No |
| 5. Dismantling of existing Aircon | ☐ Included | ☒ Not Included |
| 6. Ducting | ☐ Yes | ☒ No |

Dimension :

- Plastering, carpentry and restoration works are to be done by the customer.
- Wiring of electrical supply from main panel to air-conditioning unit are to be done by the customer.
- Processing of mechanical plan, working permit, electrical permit are to be done by the customer.
- Other concern: CUSTOMER NEED TO PROVIDE POWER SUPPLY
AT THE OUTDOOR UNIT (GRASSY)
ATTACH INSIDE THE AREA, FOR EXIST
SERVING.
ATTACH AT THE RIGHT OF INDOOR UNIT, USE OLD
COPPER TUBE WITH MAXIMUM.



Note :

- Prepared by:**

Customer Conforme:

Signature Over Printed Name