



20-Feb-2025

TOMITA INDUSTRIAL

ATTN: RACQUEL/MANUEL

#22 5/F TOYAMA GROUP CENTER, TIMOG AVENUE, BRGY. LAGING HANDA QUEZON CITY

TEL: 0923-0825868

Sir/ Madam,

This is to bill you on the service job done to your unit for the month of FEBRUARY 2025.

Details of the charges are stated below and a copy of the Service Job Report is attached for your references:

DATE ATTENDED	SJR #	QUANTITY/MODEL	SERVICE JOB DONE	AMOUNT
03-Feb-25	HO-00240628	(1) KFG-30F1	REPLACED CAPACITOR	3,250.00
TOTAL AMOUNT DUE				P 3,250.00

For any clarifications please feel free to call the Undersigned at the telephone number **8852-6473**


Note: If check payment, please prepare check payable to **Kolin Philippines International Inc.**

Account #: BDO - KALAYAAN

011808000428

Note: In case thru Bank Deposit under BDO Account, kindly indicate SJR# for your Bank Reference in the deposit slip and Fax to **(632) 8852-6473** or E-mail to: **kmi_asst@kolinphil.com.ph**

Prepared by:


Janellen S. Lim
KMI - Assistant

Noted by:


Mari Nathaniel R. Flores
KMI - Supervisor

Received by:

Signature over printed name

 **Kolin Philippines Int'l., Inc.**

Plant and Head Office:

Blk 3 Lt 5 Main Drive, FCIE Compound,
Brgy. Langkaan I, Dasmariñas, Cavite

Tel: (632) 8749-2118

Fax (046) 402-0793

 www.kolinphil.com.ph / kolinphilippines

Operation Office:

1854 Sta. Rita St., Guadalupe Nuevo,
Makati City

Tel.: (632) 8851-2711, 12 or 15

Fax: (632) 8852-2170

Sales Dept. Fax: (632) 8852-4791





Kolin Philippines Int'l., Inc.

1854 Sta. Rita St., Guadalupe Nuevo, Makati City
Tel. No.: 8852-6868 / Mobile: 0917-811-8982 / Email: service@kolinphil.com.ph
Website: www.kolinphil.com.ph

TTWR 44634

SERVICE JOB REPORT

No. HO-00240628
Previous SJR No. HO-00231600

Customer	Tomita Industrial				Date	02-03-2025			
Address	#22 5/F Toyon Group Center, Timog Ave., Bay Laging Handa, QUEZON CITY, Manila...				Start Time	01:06 pm			
Telephone No.	8355-7777		Mobile No.	0923-0825168		End Time	01:09 pm		
Contact Person	Racquel/ Manuel	Mobile No.			Tel. No.	365-7777		Relayed by	lojero
Warranty Code					Room Size			Warranty Type	C
Model	KFG-30F1				Call Origin	IO		Job Class	TS LVL 1
S/N (I)	10251004-10565		S/N (O)	11641001-11016		Permit?	<input type="checkbox"/>	Parking?	<input type="checkbox"/>
Dealer			DOP	05/28/2013		Appointment?	<input type="checkbox"/>	O.R.?	<input type="checkbox"/>
Installer			Complaint	E2 Error Code					
Location	Accounting Department	Before	After		Notes: LOJERO Findings - Defective compressor cap, fan cap indoor and outdoor and defective terminal wire. Recommendation - 2nd action for replacement of compressor cap 95uf, 35uf, fan cap 4.5uf, 35uf and terminal wire 4pc / Note: Need asap schedule. Repair Done - Check Unit / Fan / Location o/o KIM				
Mode Setting (Cool)			No. of Visit	2nd Action		Tentative Sched	02/05/2025		
WAC Setting Temp(16°C-RE)/(10/12-ME)			Findings						
SAC/PAC Setting Temp (17°)									
Discharge Temperature (High)									
Intake Temperature (High)									
Ampere			Recommendation						
Wattage (Inverter)									
Voltage									
SAC/PAC Pressure (PSI)									
Part Code	Description				Qty	Unit Price	Amount		
	Capacitor 95uf				1	550			
	Capacitor 4.5uf				1	500			
	Capacitor 3.5uf				1	300			
	Capacitor 35uf				1	600			
							1,250		
<p>DATE: <u>Feb 5, 2025</u></p>									
SR No.					Labor	1,500.00			
Repair Done	Replaced capacitor unit okay				Handling				
Repair Code					Others				
Date Attended	Feb 5, 2025		Date Finished	Feb 5, 2025		Total	3,250.00		
Time Attended	2:45 pm		Time Finished	3:45 pm		Amount Paid	by collection		
This serves as temporary receipt when properly filled up by authorized representative.					Check No.	Bank / Branch			
Served by:	Vidal Lujero, Manual Representative				By signing below, I authorize or give consent to Kolin Philippines International, Inc. and its ASC to collect, store and process my personal information for availing service as required by Data Privacy Act of 2012 and other applicable laws and regulations.				
I hereby agree to the above repair charges incurred/to be incurred to my unit and to the terms and conditions stated at the back, and that I received the unit in good working condition.					Created by: RECHILLA CSR				
Technician(s)					Conformed by: Customer (Signature over printed name)				