



SERVICE JOB REPORT

HO-00167667
HO-00154550

Customer						Date					
Address						Start Time					
						End Time					
Telephone No.						Relayed by					
Contact Person						Warranty Type					
Warranty Code						Job Class					
Model						Job Type					
S/N (I)						Permit? <input type="checkbox"/> Parking? <input type="checkbox"/> Appointment? <input type="checkbox"/>					
Dealer						O.R.? <input type="checkbox"/> Ladder? <input type="checkbox"/>					
Installer						Notes					
Location						Complaint					
Mode Setting (Cool)						Tentative Sched					
WAC Setting Temp(16°C-RE)/(10/12-ME)						Findings					
SAC/PAC Setting Temp (17°)						DISPY UNIT					
Discharge Temperature (High)						13°C					
Intake Temperature (High)						25°C					
Ampere						15A					
Wattage (Inverter)						Recommendation					
Voltage						CLEAN AIR FILTER REGULARLY G-C EVERY 3 MONTHS					
SAC/PAC Pressure (PSI)						125 PSI					
Part Code						Description					
Qty						Unit Price					
Amount											
SR No.						Labor					
Repair Done						Handling					
Repair Code						Others					
Date Attended						Total					
Time Attended						Amount Paid					
This serves as temporary receipt when properly filled up by authorized representative.						Balance					
Check No.						Bank / Branch					
Serviced by:						By signing below, I authorize or give consent to Kolin Philippines International, Inc. and its ASC to collect, store and process my personal information for availing service as required by Data Privacy Act of 2012 and other applicable laws and regulations.					
I hereby agree to the above repair charges incurred/to be incurred to my unit and to the terms and conditions stated at the back, and that I received the unit in good working condition.						Created by:					
Technician(s)						Conformed by:					
ALVIN DE RIVERA CSR						Customer (Signature over printed name)					